



--- ADDENDUM #2 ---

Issued September 5, 2023 to all bidders

To be added to and made part of the Tender Documents

**1.0 Intent**

- .1 This addendum is issued prior to closing of bids to provide revisions to the tender documents.
- .2 Such revisions shall form part of the Tender Documents and change the original Tender Documents only in the manner and to the extent stated. **A signed copy of this addendum must be attached to the Bid and the Bidder must acknowledge receipt of this addendum in the space provided.** All other specifications, terms, and conditions remain unchanged.
- .3 The statements below are for clarification purposes in response to questions received from bidders.

**2.0 Questions and Answers**

Question #1 – “Just wondering if you can officially confirm that this proposed scope of work will not require a watercourse alteration permit but rather just a work within right of way permit only.”

Answer #1 – All proposed work is to be completed outside of the watercourse channel bed, and as such, a watercourse alteration permit will not be required. This has been reviewed and confirmed with the local Nova Scotia Environment and Climate Change inspector. Care must be taken when constructing the pea gravel dams to ensure the proposed work remains isolated from the existing channel.

Kind regards,

**Alexander J. de Sousa, P.Eng.**  
Director of Engineering & Public Works  
Town of Wolfville

\_\_\_\_\_  
Representative Signature

\_\_\_\_\_  
Company

\_\_\_\_\_  
Date

-----END OF ADDENDUM #2-----